



## **IFB #08-23 Library Water Main Extension Project**

### **Addendum #2**

**Date Issued: 9/7/2023**

This document hereby forms part of the original Invitation for bids marked “**IFB 08-23 Library Watermain Extension**” that was posted on 8/17/2023 on the Town of Wilton’s Purchasing web page.

**Instructions:** Each numbered entry indicates a specific change or clarification issued by the Town of Wilton in regards to the designated IFB that may significantly affect competition or otherwise fundamentally alter the bidding process for the aforementioned project. Please read the instructions carefully and acknowledge understanding of any applicable addendums in a submitted bid package.

1. Due to addendums issued, the Town of Wilton hereby extends the bid deadline to **Monday, September 25<sup>th</sup>, 2023 at 2:00 PM**. Please amend all references to the old deadline of **Friday, September 15<sup>th</sup> 2023 at 2:00 PM to September 25<sup>th</sup> 2023 at 2:00 PM**.
2. **Question:** The Project Plans list material component conflict with the IFB’s bid sheet, which standards should the respondent follow? **Response:** The Wilton Water Commission’s standards, represented in the bid sheet, are required for this project.
3. **Question:** Are alternative material or component proposals acceptable? **Response:** No, as they do not follow the Wilton Water Commission’s accepted standards.
4. **Question:** Will the Town consider proposals where itself, the Water Commission, or Library will procure the project materials? **Response:** No. See **Page 3, Section 3**.
5. **Question:** What if a significant amount of ledge is encountered during the construction process? **Response:** See **Page 4, Section 4.1 Pricing**, and **Section 4.2 Contingency**. Dealing with ledge would be considered an appropriate use of contingency funds, and change orders may be approved by the Town Administrator.
6. **Question:** What kind of fill or material is accepted/needed for the project? **Answer:** Please see **Page 17 Attachment Item #3**. The Wilton Water Commission requires sand for backfill; all other fill requirements not described by these standards shall follow the town’s standard for roadways, which are identical to the NHDOT’s standards.